



QUEZON 1 ELECTRIC COOPERATIVE, INC.

Brgy. Pocol, Pitogo, Quezon

Telefax: (042) 318-8156

ISC-2024-014

INVITATION FOR SEALED CANVASS

September 5, 2024

Sealed Bids/Proposals/Quotations for the Supply and Delivery of the following item for QUEZELCO 1 shall be received by the Bids and Awards Committee until 5:00PM of September 12, 2024. The bids/proposals/quotations will be opened on September 13, 2024 at 9:00AM.

Quantity	Unit	Item Description	Unit Cost (Php)	Total Amount (Php)
2	unit	3 Phase Automatic Circuit Recloser 15KV, 800A w/ RC10 control		
GRAND TOTAL				

Instruction to Bidder and Terms of Condition:

The following shall be included in the offer:

1. Warranty statement. The bidder obligates, guarantees and warrants that the items to be delivered are within the standards and specifications set by the cooperative. Upon completion, there will be a 1 year warranty or more.
2. Brochure or any document showing the technical specifications of the materials offered.
3. Authorization from the manufacturer to supply the goods valid for the current year.
4. The materials offered shall comply with the required specifications (See attached material specifications)
5. Delivery period shall be within thirty (30) to forty five (45) calendar days after receipt of Notice to Proceed.
6. The financial offer shall be listed on the space provided above.
7. The financial offer shall not exceed the Approved Budget Cost of **Php 1,600,000.00**
8. The ABC is VAT inclusive and the bid price should be VAT inclusive.
9. Term of payment : 90 days upon complete delivery
10. Term of Delivery - FOB Pitogo
11. Performance Bond of 5% of contracted price shall be posted within 5 days upon receipt of notice of award.
12. Price validity - 60 calendar days
13. Penalty Clause – 1/10 of 1% (0.1%) of the cost of the unperformed portion of the contract for every day of delay)

Additional Instructions:


1. Please send your quotations thru email using the designated BAC email address quezelco1_bac@yahoo.com.ph and shall be addressed to "The Bids and Awards Committee".
2. The subject shall bear the word "**Bids for the Supply and Delivery of Automatic Circuit Recloser for Emergency Replacement in Agdangan and San Narciso.**"
3. The quotation shall be password protected. Password shall be sent on the day of opening at 8:00 am.

QUEZELCO 1 reserves the right to reject any or all bids without offering any reason, waive any defect therein and accept the offer most advantageous to the cooperative.

For further inquiries you may contact our QUEZELCO 1 BAC Secretariat, Ms. Maria Teresa Caraig at mobile number 09688520659.

Noted by:


VICTOR R. CADA
 Acting General Manager


MILAGROS H. CAYETANO
 BAC – Chairman

MATERIAL SPECIFICATION

15KV THREE PHASE RECLOSER

Technical Specification:

- Rated maximum voltage: **15 KV**
- Rated maximum Ampere: **800 A**
- Interrupter Type: **Vaccum Fault Interrupter**
- Insulation : **Aromatic epoxy resin**
- Control Cable: **10 meters**
- Bushing Type: **Silicon rubber bushing insulator**
- Fault break capacity: **12.5 kA**
- Recloser Tank composition: **Powder coated stainless steel**
- Frequency Range: **60 Hz**
- Mechanical and Full load operations: **30,000**
- Impulse withstand phase to earth and phase to phase: **110 Kv**
- Mounting Bracket: **Hot dip galvanized for recloser and control unit**
- Set of **Wi-Fi communication** with tethering device for wireless communication up to 60 meters line of sight for programming, setting, monitoring and control of recloser

Protection Functions:

- | | |
|-------------------------------|------------------------------|
| Directional Overcurrent (DOC) | Under/Over Frequency (UF/OF) |
| Earth Fault (EF) | Loss of Supply Detection |
| Overcurrent (OC) | Cold load peak up element |
| Sensitive Earth Fault (SEF) | Voltage Element Reclosing |
| Auto Reclosing Element | Voltage Reclosing Control |
| Negative Phase Sequence (NPS) | SCADA ready |
| Hot Line Tag | |
| Under/Over Voltage (UV/OV) | |
| Harmonic Protection | |

Monitoring Event Recording

- Close/Open operation
- Fault Profile
- Event Log
- Change Log
- Load Profile
- Power Quality
- Fault Counter

Prepared by:

J. Pintano
JONATHAN R. PINTANO
SMS-Head

Noted by:

R. Ponce
RODERSAN B. PONCE
OMD-Manager

QUEZON I ELECTRIC COOPERATIVE, INC.

Brgy. Pocol, Pitogo, Quezon

Accreditation Requirements

Name of Company/Supplier/Representative: _____

Address: _____

Contact Number : _____

EMAIL ADD: _____

DOCUMENTS		
1	DTI Registration name registration or SEC Registration Certificate	
2	Valid and current Mayor's Permit/Municipal License	
3	Taxpayer's Identification Number,	
4	BIR Value Added Tax Registration	
5	Certification that the bidder is not "blacklisted" or banned from bidding by the government or any of its agencies, officers, corporation or LGU's and other private corporations or electric cooperatives	
6	Compliance with EO # 398	
	a.) Proof of VAT Payments for the past six months	
	b.) Tax Clearance for the last two quarters	
7	On-going, completed or awarded contract not yet started within the relevant period specifying the following:	
	a. Name of contract	
	b. Date of contract	
	c. Amount of the contract and value of outstanding contracts	
	d. Date of delivery	
	e. End user's acceptance if completed	
8	Company Profile	
9	Latest Income Tax Return	
10	Complete set of Audited Financial Statements, stamped "received" by the BIR or its duly accredited and authorized institutions, for the immediately preceding calendar year, showing, among others, the prospective bidder's total and current assets and liabilities	
11	Articles of Incorporation, Partnership or Cooperation, whichever is applicable	
12	A certification under oath from the bidders responsible officers that the bidders is free and clear of all liabilities with the government	
13	Valid Registration with Philippine Contractor Accreditation Board (PCAB) with specialization in electrical works and with at least small B size range Classification (C and D category)- for contractor only	

Email Address:

quezelco1_bac@yahoo.com.ph